

BIDS AND AWARDS COMMITTEE FOR INFRASTRUCTURE (BAC-I)

**Bidding for the Construction of Two (2) Units Deep Well at Wallace Air
Station, San Fernando La Union**

**BID BULLETIN NO. 1
03 September 2021**

This Bid Bulletin clarifies queries raised during the pre-bid conference (via Zoom) and additional queries (if any) received by the BAC-I through email until the deadline for clarification on 27 August 2021. This also contains further clarifications and modifications which shall form an integral part of the Bid Documents.

I. General Queries

Questions/Concerns	Clarifications									
<p>1. Are percussion and rotary drilling rigs both required for the minimum equipment or do either of the two drilling rigs constitute compliance?</p>	<p>The drilling of the deep wells shall be performed with the percussion drilling method. Please refer to the amendment below for the minimum required equipment.</p> <p>Section III. Bid Data Sheet ITB Clause 10.5</p> <p>xxx</p> <table border="1" data-bbox="831 1469 1465 1995"> <thead> <tr> <th data-bbox="831 1469 1043 1619">Minimum Required Equipment</th> <th data-bbox="1043 1469 1254 1619">Capacity</th> <th data-bbox="1254 1469 1465 1619">Quantity</th> </tr> </thead> <tbody> <tr> <td data-bbox="831 1619 1043 1809">Drilling Rig, percussion Type, Diesel Engine</td> <td data-bbox="1043 1619 1254 1809">With a Borehole of 16" diameter</td> <td data-bbox="1254 1619 1465 1809">1</td> </tr> <tr> <td data-bbox="831 1809 1043 1995">Rotary Drilling Machine</td> <td data-bbox="1043 1809 1254 1995">With a Borehole of 24" diameter</td> <td data-bbox="1254 1809 1465 1995">1</td> </tr> </tbody> </table>	Minimum Required Equipment	Capacity	Quantity	Drilling Rig, percussion Type, Diesel Engine	With a Borehole of 16" diameter	1	Rotary Drilling Machine	With a Borehole of 24" diameter	1
Minimum Required Equipment	Capacity	Quantity								
Drilling Rig, percussion Type, Diesel Engine	With a Borehole of 16" diameter	1								
Rotary Drilling Machine	With a Borehole of 24" diameter	1								

	xxx
2. Can the Philippine Statistics Authority Consumer Price Index (PSA CPI) be applied to adjust the contract value of the Single Largest Completed Contract (SLCC)?	Yes. The SLCC may be adjusted to current prices using the PSA CPI.
3. On the design and methodology, as published, a percussion drilling method is to be adopted. Is it possible to modify the methodology and adopt a rotary drilling method?	No. For the purpose of this bidding, the design and scope of work for drilling as indicated in the Bill of Quantities are specific for percussion drilling.
4. Is there a possibility to change the casing part and conductor type? The boreholes need to be widened so that we could place the pilot hole to rig it.	No. Reaming of the pilot hole is specific for the rotary drilling method. The preliminary well design is based on the percussion drilling method.
5. Is the purchase of bidding documents in Clark only? Will you allow the prospective bidders, especially those coming from Baguio, to purchase bidding documents in San Fernando La Union?	<p>Purchase of bidding documents is through an online or cash payment.</p> <p>For online payment, the BAC Secretariat shall send the bank details to the interested bidders upon request and should notify the BAC Secretariat, through email, of its proof of payment to be authorized to join the bidding. The following email addresses are:</p> <ol style="list-style-type: none"> 1. baci2021@bcda.gov.ph 2. mrpaclar@bcda.gov.ph

	For cash payment, BCDA shall accommodate over-the-counter transactions for interested bidders who opt to purchase bidding documents on the day of Opening of Bids at the BCDA Office, BCDA Corporate Center 9/F One West Aeropark Building, Industrial Estate 5, Clark Global City, Clark Freeport Zone, Mabalacat 2023 Pampanga on 10 September 2021, Friday, from 8:00 am to 12:00 Noon.
6. Please confirm if the submission of the bids is either in Clark or BTC?	The manual submission of Bids is at the BCDA Office, BCDA Corporate Center 9/F One West Aeropark Building, Industrial Estate 5, Clark Global City, Clark Freeport Zone, Mabalacat 2023 Pampanga It is encouraged to submit bids before the deadline of submission which is on 10 September 2021, at 12:00 Noon
7. Should Joint Venture contracts be declared in the statement of all ongoing contracts?	Yes. All ongoing government and private contracts, including contracts acquired through partnerships and joint ventures, must be declared.

II. Clarifications

- A. Approved Budget for the Contract (ABC): Php 14,598,000.00, inclusive of all applicable taxes and fees. Bids in excess of the ABC shall be automatically rejected at the bid opening.
- B. The bid documents can be accessed from the PhilGEPS and BCDA Website.
- C. The bidders are requested to use tabs in compiling their bid documents for quick and easy identification and verification.

D. Composition of the Bidding Documents

First Envelope: Technical Proposal

1. PhilGEPS Certificate of Registration under Platinum Membership.
2. Statement of all ongoing government and private contracts, including contracts, awarded but not yet started, if any, whether similar or not similar in nature and complexity to the contract to be bid. Shall be supported by contracts or notices of award or notices to proceed.
3. Statement of Single Largest Completed Contract for Construction of Deep Wells, equivalent to at least fifty percent (50%) of the ABC. Shall be supported by contract, CPES rating which must be at least Satisfactory (if applicable), certificate of completion, or owner's acceptance.
4. Special PCAB License if in case of joint ventures and registration for Category "A" and classification "Medium B".
5. NFCC computation is at least equal to the ABC.
6. Valid Joint Venture Agreement, in case of Joint Ventures.
7. Valid Bid Security.
8. Organizational Chart for the contract.
9. List of contractor's personnel nominated/to be assigned to the project.
10. List of contractor's equipment (owned, leased, and/or under purchase agreement) supported by a certification of availability of equipment from the lessor/vendor for the duration of the project.
11. Notarized Omnibus Sworn Statement.

Second Envelope: Financial Proposal

1. Financial Bid.
2. Bid Prices in the Bill of Quantities.
3. Daywork Rates
4. Detailed Cost Estimates/Detailed Unit Price Analyses
5. Cash Flow and Payment Schedule.

III. Reminders:

A. Reasons for Disqualification:

1. Non-declaration of all ongoing contracts

2. Incurring a negative slippage of at least 15% in any one project or at least 10% in each of 2 or more contracts
 3. Failure to present the exact equipment pledged in their bid submission due to various reasons
 4. Declaration of SLCC not contracted/completed
 5. Nomination of Key Personnel who has no valid license or does not meet the required qualifications
 6. Falsification of documents in the bid submission
- B. Receipt of Bids. Bids must be duly received by the BAC Secretariat through manual submission at BCDA Office, BCDA Corporate Center, 9/F One West Aeropark Building, Industrial Estate 5, Clark Global City, Clark Freeport Zone, Mabalacat 2023 Pampanga, on or before 12:00 Noon of September 10, 2021. Late bids shall not be accepted.

The bidders may submit their bid proposal before the deadline for submission of bids to avoid late submission.

- C. Opening of Bids. Bid Opening shall be on 10 September 2021, 1:00 PM at BCDA Office, BCDA Corporate Center, 9/F One West Aeropark Building, Industrial Estate 5, Clark Global City, Clark Freeport Zone, Mabalacat 2023 Pampanga, and/or through <https://zoom.us/j/97690258375?pwd=YW52ajg5NzRRMjFDN0U4aWZSblNFZz09> with Meeting ID: 976 9025 8375 and Passcode: 385553. Bids will be opened in the presence of the bidders' representatives who choose to attend the activity.

To adhere to the maximum capacity required for the face-to-face conference and maintain social distancing, the Bidders are only allowed to send one (1) representative each, to assist in and witness the opening of bid proposals.

The bidder's representative shall be required to present the necessary documents before entry to the venue of the Opening of Bids, such as Vaccination Card, a negative Antigen/RT PCR test results, Government issued ID, and others, as required under a Memorandum Circular dated 19 August 2021 issued by the Clark Development Corporation.

All provisions and statements in the bidding documents inconsistent with this Bid Bulletin are either modified or rendered ineffective, as the case may be.

Issued on 03 September 2021

BIDS AND AWARDS COMMITTEE FOR INFRASTRUCTURES (BAC-I)

ATTY. MARIA SOLEDAD C. SAN PABLO
Acting Chairperson

BACI2021-0128