

**BIDS AND AWARDS COMMITTEE FOR INFRASTRUCTURE PROJECTS (BAC-I)**

**BIDDING FOR THE CONSTRUCTION OF ROADS, UTILITIES AND PREPARATORY  
WORKS AT MORONG DISCOVERY PARK**

**BID BULLETIN NO. 7**

This Bid Bulletin contains clarifications for various queries from prospective bidders, and other matters relating to the Project and shall form an integral part of the Bidding Documents.

**I. Prescribed Bid Form for the duly notarized statements from all the potential Joint Venture partners stating that they will enter into and abide by the provisions of the JVA (Joint Venture Agreement) in case they win the bid.**

For the benefit of all prospective bidders, attached herewith in **Annex A** for the prescribed bid form for the duly notarized statements from all the potential joint venture partners stating that they will enter into and abide by the provisions of the JVA in case they win the bid, which can also be accessed through the link below:

Link:

<https://docs.google.com/document/d/16BfGPA6d95pflivcBIf4QspLIMNDNwXy/edit>

**II. Queries/Questions by the Prospective Bidders**

Queries/Questions	Clarifications / Responses
<p><b>Q1. DUPA requirement</b></p> <p>In Bid Bulletin no. 4 and in the bidding documents we noticed inconsistencies on the issue of the Detailed Unit Price Analysis (DUPA). The Financial Component Envelope indicated in the Bid documents mentioned the inclusion of Duly accomplished Detailed Cost Estimates. However, the reply on Q19 in the Bid Bulletin no. 4 say "DUPA is not required in the Bid Submission. However, it should be submitted to BCDA within one month after the issuance of the Notice to Proceed (NTP) to the winning bidder."</p> <p>In this regard, may we request clarifications.</p>	<p>Detailed Unit Price Analysis (DUPA) is different with the Detailed Cost Estimates (DCE).</p> <p>For the DCE, this form should be included in the Financial Component envelope pursuant to Clause 11.1 of the Bid Data Sheet (BDS), which states that:</p> <p><i>"In addition to the Bid Form and Bill of Quantities, the following <b>shall be included in the Financial Component</b>:</i></p> <p>1. <i>Detailed Cost Estimates prescribed in 'Annex P' "</i></p> <p>Please refer to "<b>Annex P</b>" of the Bidding Documents for the form of the DCE. On the other hand, for the DUPA, this form should be submitted within one (1) month after issuance of NTP, pursuant</p>

	<p>to Clause 21 of the BDS, which states that:</p> <p><i>"the contractor must also <b>submit the Detailed Unit Price Analysis within one month</b> after the issuance of the Notice to Proceed to the winning contractor".</i></p> <p>The form for the DUPA will be provided and discussed during the project's kick-off meeting.</p>
<p>Q2. Submission of Special PCAB License</p> <p>Please clarify if the special PCAB License should be attached to the technical component of the bidding documents or could be submitted during post-qualification?</p>	<p>For an existing Joint Venture/Consortium, the Special PCAB License should be included in the Technical Component envelope of its bid. Please refer to <b>Section I, Item I</b> of Bid Bulletin No.5 for the amendment of the Checklist of Technical Component Envelope.</p>
<p>Q3. Format of Curriculum Vitae</p> <p>For the format of the Curriculum Vitae, If a proposed key Technical Personnel is not an employee, do we have to fill out the "Current Position in the firm" and "years with the firm", put N/A, or leave it blank?</p>	<p>If a proposed key personnel is not an employee, state '<b>Not Applicable</b>' in the field of '<b>Current Position in the Firm</b>' and '<b>Years with Firm/Entity</b>'.</p> <p>In addition, per Item 3 of the BDS Clause 10.4, the said key personnel shall submit a Certification duly signed by him/her that he/she will work for the bidder if the latter is awarded the contract for the project.</p> <p>Please refer to Annex "D-2" in the Bidding Documents for the said Certification</p>
<p>Q4. Definition of JV</p> <p>Please provide definition of "<b>existing JV</b>" and "<b>potential JV</b>".</p>	<p>An <b>existing joint venture</b> is a partnership that is already established and has a valid joint venture agreement (JVA)</p> <p>On the other hand, a <b>potential joint venture</b> refers to a proposed partnership that has not yet been established and will enter into a JVA in case they win the bid.</p>
<p>Q5. Item 5(BB#4): Joint Venture and PCAB License</p> <p>a. "For Consortium Bidders-PCAB</p>	<p>Yes. It should submit a duly signed Consortium Agreement and their Special PCAB license which should</p>

<p><i>Special License shall be submitted with the Bid.</i></p> <p>Is the above statement correct</p>	<p>meet the minimum qualification of License "AAA" Category for General Engineering and License Classification of "Large B" for Horizontal Structures (Roads, Highways, Pavement, Railways, Airport Horizontal Structures and Bridges)</p>
<p>Q6. Item 5(BB#4): Joint Venture and PCAB License</p> <p>b. <i>"For Joint Venture Bidders-PCAB Special License shall be submitted upon award."</i></p> <p>Is the above statement correct?</p>	<p>Yes. In case of a joint venture, it should submit a duly signed Joint Venture Agreement and their Special PCAB license which should meet the minimum qualification of License "AAA" Category for General Engineering and License Classification of "Large B" for Horizontal Structures (Roads, Highways, Pavement, Railways, Airport Horizontal Structures and Bridges)</p>
<p>Q7. Item no. 604(4)b.2</p> <p>Drawing for item no. 604(4)b.2 Structural Works- ALTERNATE ENTRANCE / EXIT GATE NO. 2, INCLUDES PEDESTRIAN GATE AND FENCE, H = 3.0 m from top of F.G.L, TOTAL LENGTH 22.0 m., includes 100 x 75 x 4 mm thk. tubular bar frame, 50 x 75 x 4 mm thk. horizontal tubular frame, 50 x 50 x 4.0 mm thk. vertical tubular bar, painting works and other items to complete the work.</p>	<p>Please refer to the consolidated plan for Bldg. 9 provided in the link below:</p> <p><a href="https://drive.google.com/file/d/1IKDXpnB7XxbE8SNZdqsVwPh926KGMBFu/view?usp=sharing">https://drive.google.com/file/d/1IKDXpnB7XxbE8SNZdqsVwPh926KGMBFu/view?usp=sharing</a></p>
<p>Q8. Item A.1.3(1).</p> <p>Queries on A.1.3(1) indicated in general requirement technical specification but not indicated in BOQ.</p>	<p>Item A.1.3(1) is not included in the pay items under General Requirements. BOQ shall govern.</p>
<p>Q9. On- Floor Cabinets</p> <p>Drawing/details of On- Floor Cabinets at Reception Counter</p>	<p>Please use 1-20mm thick plyboard tabletop laminate finish with all the hardwares and accessories needed to complete the works. Size 1 - 300mm W x 1025mm H, 1 - 400mm W x 720mm H</p>
<p>Q10. Tabletop</p> <p>Drawing/details of 20mm thk Tabletop at Guardhouse</p>	<p>Please refer to Architectural Drawing Sheet Nos. A8-11 and A9-12 for the</p>

	details of the tabletop.
<p>Q11. Title of the Project.</p> <p>The Title of Project in BOQ is Discovery Park but in the given drawing plan is Technology Park.</p>	<p>"Bataan Technology Park" was the former name of Morong Discovery Park.</p>
<p>Q12. Electrical Works 1103(3)r. Type "H", Flood Light with 40W LED Lamp/s, 230V, 60Hz.</p> <p>1. There is no TYPE H in the drawing. Should it be TYPE D or not?</p>	<p>Type H refers to the flood light with 40W LED Lamp, 230V, 60Hz.</p> <p>Please refer to the revised electrical drawing lighting fixture schedule.</p> <p><a href="https://drive.google.com/file/d/1esUgd4ifzcvNWTQL77ljQ3GVz3SFy9St/vi ew?usp=sharing">https://drive.google.com/file/d/1esUgd4ifzcvNWTQL77ljQ3GVz3SFy9St/vi ew?usp=sharing</a></p>
<p>Q13. Drawing for item no. 604(4)b.2 Structural Works- ALTERNATE ENTRANCE / EXIT GATE NO. 2, INCLUDES PEDESTRIAN GATE AND FENCE, H = 3.0 m from top of F.G.L, TOTAL LENGTH 22.0 m., includes 100 x 75 x 4 mm thk. tubular bar frame, 50 x 75 x 4 mm thk. horizontal tubular frame, 50 x 50 x 4.0 mm thk. vertical tubular bar, painting works and other items to complete the work</p>	<p>Please see response in Q7 of this Bid Bulletin.</p>
<p>Q14. Item 4 (BB#4): Minimum required equipment TANDEM VIBRATORY STEEL DRUM ROLLER 10 TONS</p> <p>Can we also use "SINGLE SMOOTH VIBRATORY ROLLER 10T"?</p>	<p>No. Only Tandem Vibratory Steel Drum Roller with at least 10 tons of capacity will be accepted for this bidding.</p>
<p>Q15. We would like to clarify the reference for Schedule B.1, B.2, C, D, F</p>	<p>Please refer to the Technical Specifications for the General Requirements, as follow:</p> <ol style="list-style-type: none"> <li>Schedule B-1 - Furniture, Fixtures, Office Equipment and Appliances for the Field Office of CMS Staff- Rental Basis</li> <li>Schedule B-2 - Furniture, Fixtures, and Appliances for the Living Quarters for the Engineer / BCDA Staff- Rental Basis</li> </ol>

	<p>3. Schedule C - Provision of Supplies And Consumable Stores for Off-Site Field Office and On-Site Living Quarters of the Engineer/ BCDA Staff</p> <p>4. Schedule D - Service Vehicles for the Engineer/ BCDA Staff</p> <p>5. Schedule F – Communication Equipment for The Engineer/ BCDA Staff</p>
<p>Q16. Request for Extension.</p> <p>We would like to request an extension on the deadline for submission of bid proposal for the above project to <b>March 27, 2023</b>, instead of march 20, 2023 for us to further review and finalize our bid.</p>	<p>There will be <b>no more extension</b> on the date of the 'Submission of bids' and the 'Opening of Bids' which are scheduled on 20 March 2023.</p>
<p>Q17. Request for Extension.</p> <p>We are writing your good office to formally request a <b>fifteen (15) days extension</b> of submission and opening of bids regarding <b>security post tower and elevated water tank</b>. Since it is not included in the Bill of Quantities (BOQ). But it is included in the site development, since the queries are <b>not answered yet</b>. This may give us time to fully complete all the required items.</p>	<p>There will be <b>no more extension</b> on the date of the 'Submission of bids' and the 'Opening of Bids' which are scheduled on 20 March 2023.</p>
<p>Q18. Request for Extension.</p> <p>May we request a <b>fourteen (14) days extension</b> of submission and opening of bids</p>	<p>There will be <b>no more extension</b> on the date of the 'Submission of bids' and the 'Opening of Bids' which are scheduled on 20 March 2023.</p>
<p>Q19. Request for Extension.</p> <p>We kindly request to extend the bid submission deadline to <b>27 March 2023</b>. We assure you that this extension will be used to finalize our technical requirements and ensure the quality of our submission.</p>	<p>There will be <b>no more extension</b> on the date of the 'Submission of bids' and the 'Opening of Bids' which are scheduled on 20 March 2023.</p>

All other provisions in the Terms of Reference and statements in the Bidding Documents or previous Supplemental/Bid Bulletin/s that are inconsistent with this Bid Bulletin are deemed amended or modified.

Issued on 13 March 2023.

**BIDS AND AWARDS COMMITTEE FOR INFRASTRUCTURE (BAC-I)**

  
**ATTY. GISELA Z. KALALO**  
Chairperson

Uncontrolled when printed or emailed

# Annex A

Prescribed Bid Form for the duly notarized statements from all the potential joint venture partners stating that they will enter into and abide by the provisions of the JVA in case they win the bid

Uncontrolled when printed or emailed

## Commitment to Execute a Joint Venture Agreement

REPUBLIC OF THE PHILIPPINES )  
CITY/MUNICIPALITY OF \_\_\_\_\_ ) S.S.

### AFFIDAVIT

We, the affiants named below, of legal age, after having been duly sworn to in accordance with law, do hereby depose and state that:

1. We are the duly authorized and designated representatives of the following entities that intend to participate in the [Name of the Project] of the [Name of the Procuring Entity] as a Joint Venture:

<i>Name of Joint Venture Partners</i>	<i>Percentage of Participation</i>

2. We are granted full power and authority to form a Joint Venture and enter into a Joint Venture Agreement and perform any and all acts necessary to participate, submit, and to sign and execute this commitment, as shown in the attached [state title of attached document showing proof of authorization (e.g., duly notarized Secretary's Certificate, Board/Partnership Resolution, or Special Power of Attorney, whichever is applicable)];
3. We will enter into and abide by the provisions of the JVA, as prescribed in Annex I-1 of the Bidding Documents, and perform the obligations under the contract as a Joint Venture in the instance that the bid is awarded to us; and
4. We will comply with the submission of required documents under Sec. 37.1.4 of the revised Implementing Rules and Regulations of Republic Act No. 9184 otherwise known as the Government Procurement Reform Act as a Joint Venture.
5. The affiants have no further statements.

**IN WITNESS WHEREOF**, we have hereunto set my hand this \_\_\_ day of \_\_\_, 20\_\_ at \_\_\_\_\_, Philippines.

<b>NAME OF AUTHORIZED REPRESENTATIVE</b>	<b>NAME OF AUTHORIZED REPRESENTATIVE</b>
[Designation] [Name of Company]	[Insert signatory's legal capacity] [Name of Company]
Affiant	Affiant

**[Jurat]**

*[Format shall be based on the latest Rules on Notarial Practice]*

Note:

Add more signatories if there are more than two (2) JV partners